

Certificate of Product Approval

Certificate Number: 1330d-(cl-4)

Issue: 02

Tanda Development Pte. Ltd

21 Bukit Batok Crescent
#15-75 Wcega Tower
Singapore
658065



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

TX7300

TX7302

(Refer to Appendix for details)

Standards

EN 54-3:2014+ A1:2019

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan

Signed for BRE Global Ltd

Verifier

19 January 2023

Date of Issue

23 December 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1330d-(cl-4)

Issue: 02

Tanda Development Pte. Ltd

Certified Product	Description	LPCB Ref.No.
TX7300	Addressable Sounder Strobe (TX7300 base) Notes: 1. Approved to Type A Indoor use only. 2. Meets the requirements of EN 54-3 at the following tones: - Tone 14, 2400 Hz – 2900 Hz @ 3Hz - Tone 16, 500Hz – 1200Hz, 3.5s on/0.25s off - Tone 17, 800Hz, 1s off/1s on 3. The strobe function is not approved to EN 54-23	1330d/01
TX7302	Addressable Sounder Base Notes: 1. Approved to Type A Indoor use only. 2. Meets the requirements of EN 54-3 at the following tones: - Tone 14, 2400 Hz – 2900 Hz @ 3Hz - Tone 16, 500Hz – 1200Hz, 3.75s on/0.25s off - Tone 17, 800Hz, 1s off/1s on The strobe function is not approved to EN 54-23	1330d/02

Base

TX7300 Sounder Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

19 January 2023

Date of Issue

23 December 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


